

July 1, 2024

**Almanor Heights Mutual Water Co.**  
 Attn: John Fourcroy  
 2737 Scott Dr  
 Prattville, CA 95923

**Coliform Bacteria Analysis**

Lab No. : CH 2474721 1-3  
 Customer No. : 7009457

System Number : N/A  
 Project Name : Almanor Heights Mutual Water Co.

**Analytical Results**

ID	Sample Description	Total	Fecal	E. Coli	Units	Method	Prep	Footnote
1	Tank Outflow	Absent	---	Absent	A/P/100ml	SM 9223B	Colilert-P/A 18	
2	2704 Terrace	Absent	---	Absent	A/P/100ml	SM 9223B	Colilert-P/A 18	
3	2368 Ashley DR	Absent	---	Absent	A/P/100ml	SM 9223B	Colilert-P/A 18	

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

**Result Interpretation**

The samples listed above were Acceptable for both Total and Fecal Coliform

**Sample Handling Information**

ID	Sample Number	System Number	Sample Type/Reason	Sampler	Employed By	Sampled
1	CH 2474721-001	N/A	System-Repeat	Travis Graham	FGL Environmental	2024-06-12 09:10
2	CH 2474721-002	N/A	System-Repeat	Travis Graham	FGL Environmental	2024-06-12 09:15
3	CH 2474721-003	N/A	System-Repeat	Travis Graham	FGL Environmental	2024-06-12 09:25

**Field Analysis/QA Information**

ID	Sample Description	Cl Total/Free	Temp	Analysis Started	Analysis Completed	Contact	Contacted
		mg/l					
1	Tank Outflow	---/---	---	2024-06-12 16:26 zmp	2024-06-13 10:49 kx1	N/R	
2	2704 Terrace	---/---	---	2024-06-12 16:26 zmp	2024-06-13 10:49 kx1	N/R	
3	2368 Ashley DR	---/---	---	2024-06-12 16:28 zmp	2024-06-13 10:49 kx1	N/R	

Analyses were performed at the FGL Chico Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call.

Prepared By: RRH  
 cc:PCEH

Reviewed and  
 Approved By

**Raquel R. Harvey**



Digitally signed by Raquel R. Harvey  
 Title: Tech Director Microbiology  
 Date: 2024-07-01